



Please Reply To:

AmeriSci New York

117 EAST 30TH ST.

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

LABORATORY ELECTRONIC TRANSMITTAL

To: Robert Brown
Hygenix, Inc.
Fax #:

Email: jwitchell@pennoni.com

From: Valeriu Voicu
AmeriSci Job #: 222123399
Subject: PLM 48 hour Results
Client Project: BETPS22002; Bethel Public
Schools; Bethel High School -
Bethel, CT

Date: Monday, January 2, 2023
Time: 10:26:44
Comments:

Number of Pages: _____
(including cover sheet)

NOTE: Attached report is to be considered preliminary until final review with accompanying analysis summary letter is issued.

CONFIDENTIALITY NOTICE: Unless otherwise indicated, the information contained in this communication is confidential information intended for use of the individual named above. If the reader of this communication is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is prohibited. If you have received this communication in error, please immediately notify the sender by telephone and return the original message to the above address via the US Postal Service at our expense. Samples are disposed of in 60 days or unless otherwise instructed by the protocol or special instructions in writing. Thank you.

Certified Analysis Service 24 Hours A Day • 7 Days A Week Competitive Prices
visit our web site - www.amerisci.com

Boston • Los Angeles • New York • Richmond



PLM Bulk Asbestos Report

Hygenix, Inc.
 Attn: Robert Brown
 49 Woodside Street
 Stamford, CT 06902

Date Received 12/30/22 AmeriSci Job # 222123399
 Date Examined 01/02/23 P.O. #
 Page 1 of 2
 RE: BETPS22002; Bethel Public Schools; Bethel High School -
 Bethel, CT

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1229-01 1	222123399-01 Location: Room 323 / Inside Wall @ Column - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Beige, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 10%, Fibrous glass 5%, Non-fibrous 85%			
1229-02 1	222123399-02 Location: Room 329 / Inside Wall @ Column - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 65%, Non-fibrous 35%			
1229-03 1	222123399-03 Location: Room 328 / Inside Wall @ Column - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Brown, Heterogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass Trace, Non-fibrous 100%			
1229-04 2	222123399-04 Location: Inside HVAC Chase Outside Room 323 - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 80%, Non-fibrous 20%			
1229-05 2	222123399-05 Location: Inside HVAC Chase In 3rd Floor Stairs - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Beige, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100%			


PLM Bulk Asbestos Report

BETPS22002; Bethel Public Schools; Bethel High School -
Bethel, CT


Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1229-06 3	222123399-06 Location: Room 217 / Inside Wall @ Column - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Beige, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100%			
1229-07 3	222123399-07 Location: Room 221 / Inside Wall @ Column - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Beige, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100%			
1229-08 4	222123399-08 Location: Room 103 / Inner Wall / Inside Wall @ Column - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Brown, Heterogeneous, Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 2%, Non-fibrous 98%			
1229-09 4	222123399-09 Location: Room 103 / Outer Wall / Inside Wall Chase - Spray-On	No	NAD (by CVES) by Valeriu Voicu on 01/02/23
Analyst Description: Gray/Brown, Heterogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass Trace, Non-fibrous 100%			

Reporting Notes:

Analyzed by: Valeriu Voicu
Date: 1/2/2023



Reviewed by: Valeriu Voicu



*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop, (SOF-V) = Sprayed On Fireproofing containing Vermiculite; (SM-V) = Surfacing Material containing Vermiculite; PLM Bulk Asbestos Analysis using Olympus, Model BH-2 Pol Scope, Microscope, Serial #: 223705, by Appd E to Subpt E, 40 CFR 763 quantified by either CVES or 400 pt ct as noted for each analysis (NVLAP 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite, or ELAP 198.6 for NOB samples, or EPA 400 pt ct by EPA 600-M4-82-020 (NY ELAP Lab 11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. RI Cert AAL-094, CT Cert PH-0186, Mass Cert AA000054, NJ Lab ID #NY031.

_____END OF REPORT_____

ASBESTOS PLM BULK SAMPLE LOG

Client: Bethel Public Schools

Type: PLM

Site: Bethel High School (BETPS22002)



Tech: JT

Bethel, CT

Date: 12/29/22



49 Woodside Street
 Stamford, CT 06902
 (203) 324-2222 (phone) (203) 324-3876 (fax)

LAB ID#	SAMPLE #	SAMPLING LOCATION	DESCRIPTION	QTY.	RESULT
	1229-01	Room 323 - Inside Wall @ Column	Spray-on		
	1229-02	Room 329 - Inside Wall @ Column	Spray-on		
	1229-03	Room 328 - Inside Wall @ Column	Spray-on		
	1229-04	Inside HVAC Chase Outside Room 323	Spray-on		
	1229-05	Inside HVAC Chase in 3 rd Floor Stairs	Spray-on		
	1229-06	Room 217 - Inside Wall @ Column	Spray-on		
	1229-07	Room 221 - Inside Wall @ Column	Spray-on		
	1229-08	Room 103 - Inner Wall, Inside Wall @ Column	Spray-on		
	1229-09	Room 103 - Outer Wall, Inside Wall Chase	Spray-on		
CHAIN OF CUSTODY					
Relinquished By: 	Date/Time:	Received By: 	Date/Time:		
			12/30/22 14:12		
Notes: T11 Positive. 48 Hour TAT					
jtwitchell@pennoni.com					

222 1 2 3 3 9 9