

---

**minutes from BOS meeting on 6.18.2024**

---

**Eric Swenson** <swensone@bethel-ct.gov>  
To: Mary Churchill <churchillm@bethel-ct.gov>

Thu, Jun 20, 2024 at 4:18 PM

Mary,

With regard to the Town Hall Energy Management Controls item, here are a couple follow ups based on the questions that Bryan Terzian asked at the meeting:

1. The Annual Cost Savings at the Municipal Center was estimated at \$13,917 once the VFDs and all the controls are up and running, when compared to before the VFDs were installed.
2. The other thing I wanted to pass on from Greg Rux is that this will allow him to see and monitor the status of the various zones throughout the building. Without it, he has to diagnose and troubleshoot manually.

Can you please pass this on to Bryan Terzian? Thanks.

Eric

**Eric M. Swenson**

*Director of Public Works, Town of Bethel*

*Office: 203.794.8549*

*swensone@bethel-ct.gov*

[Quoted text hidden]